

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 129

Dated: 30.04.2025

It is certified that an inspection team headed byJUNIOR ENGINEER, Mrs. BIPIN Kr.

(Name of Officers with designation) from P.H.E.D. DIVISION LAKHISARAI

(Name of Department/ Office) inspected the CREATIVE MINDS INTERNATIONAL SCHOOL ,

NH 80, RAMNAGAR, NEAR SURAJGARHA BAAZAR, AT +PO- SURAJGARHA,

DIST-LAKHISARAI, 811106 (Name & Address of the school) on25.04.2025 (date of

inspection), checked the water test report submitted by the school and found that the school has potable

drinking water for students and staff of the institution and is having provision for running water in the

toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period ofOne Year.

Signature with Seal:2.5.25

Mr. Srinivas Singh (Asst. Eng.)

Name :सहायक अभियंता

लोक स्वास्थ्य अवर प्रमंडल

Designation :लखीसराय

Assistant Engineer of

the Govt. Public Health Department (PHED)/

Authorised officer of the Local Body

Name & Address of the Office / Department :

P.H.E.D. DIVISION LAKHISARAI

BHAR - 811311

To


CREATIVE MINDS INTERNATIONAL SCHOOL


NH 80, RAMNAGAR, NEAR SURAJGARHA BAAZAR,

AT+PO- SURAJGARHA, DIST-LAKHISARAI , 811106

(Name & Address of the Institution)

Water Quality Report																			
Name of Division:- P.H.-Division, Lakhisarai				District:- Lakhisarai				Sample reporting Date :- 30.04.25											
Reference number:- PHD-660 Date:-17.04.25				Sample Submitted by:- JE				Sample received Date :- 25.04.2025											
PHYSICO-CHEMICAL & BACTERIOLOGICAL TEST REPORT																			
Sl. No	Block Name	Place	Location Detail	Type of Source	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	so ₄	Alka	As	No ₃	fe	T Coli	Remarks
Unit						NTU	umhol cm	Mg/l	Mg/l	Mg/l	Mg/l	Mg/l	Mg/l	Mg/l	Mg/l	Mg/l	Mg/l	CFU/100 ml	
Desirable Limit*(IS 10500:2012)					6.5-8.5	1.00	.	500	200	75.00	30.00	250.00	200.00	200.00	0.010	45	0.3	-	
Permissible Limit in absence of alternate source					NR	5.00	.	2000	600	200.00	100.00	1000.00	400.00	600.00	NR	NR	1	-	
1	surajgaraha	CBSE SCHOOL	CREATIVE MINDS INTERNATIONAL SCHOOL	Drinking water	6.90	1.00	98.46	88	28	11.20	3.88	14.00	1.00	12.00	BDL	1.4	0.11	-ve	


 Research Assistant (Chemist)
 P.H.-Division, LAKHISARAI


 Assistant Engineer CUM (TM)
 P.H.Division, Lakhisarai